

Hohenwald Water System Water Quality Report for 2022

Is my drinking water safe?

Yes, our water meets all of EPA's health standards. We have conducted numerous tests for over 80 contaminants that may be in drinking water. As you'll see in the chart on the back, we only detected 10 of these contaminants. We found all of these contaminants at safe levels.

What is the source of my water?

Your water, which is ground water, consists of three wells, comes from the Highland Rim Area. Our goal is to protect our water from contaminants and we are working with the State to determine the vulnerability of our water source to **potential** contamination. The Tennessee Department of Environment and Conservation (TDEC) has prepared a Source Water Assessment Program (SWAP) Report for the untreated water sources serving water to this water system. The SWAP Report assesses the susceptibility of untreated water sources to **potential** contamination. To ensure safe drinking water, all public water systems treat and routinely test their water. Water sources have been rated as reasonably susceptible, moderately susceptible or slightly susceptible based on geologic factors and human activities in the vicinity of the water source. The Hohenwald Water System sources rated as reasonably susceptible to potential contamination.

An explanation of Tennessee's Source Water Assessment Program, the Source Water Assessment summaries, susceptibility scorings and the overall TDEC report to EPA can be viewed online at <https://www.tn.gov/environment/program-areas/wr-water-resources/water-quality/source-water-assessment.html> or you may contact the Water System to obtain copies of specific assessments.

A wellhead protection plan is available for your review by contacting Roger Newton at the Hohenwald Water System between 7:00 A.M. to 4:00 P.M. weekdays.

Why are there contaminants in my water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Este informe contiene información muy importante. Tradúscalo o hable con alguien que lo entienda bien.

For more information about your drinking water, please call Roger Newton at 931-796-2231.

How can I get involved?

Our Water Board meets on the first Tuesday of every month at 5:00p.m. at City Hall. Please feel free to participate in these meetings.

Is our water system meeting other rules that govern our operations?

The State and EPA require us to test and report on our water on a regular basis to ensure its safety. We have met all of these requirements. Results of unregulated contaminant analysis are available upon request. We want you to know that we pay attention to all the rules.

Other Information

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA and the Tennessee Department of Environment and Conservation prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Do I Need To Take Special Precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have under-gone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about not only their drinking water, but food preparation, personal hygiene, and precautions in handling infants and pets from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead in Drinking Water

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Hohenwald Water System is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://epa.gov/safewater/lead>.

Water System Security

Following the events of September 2001, we realize that our customers are concerned about the security of their drinking water. We urge the public to report any suspicious activities at any utility facilities, including treatment plants, tanks, fire hydrants, etc. to 931-796-2231.

Think before you flush!

Flushing unused or expired medicines can be harmful to your drinking water. Properly disposing of unused or expired medication helps protect you and the environment. Keep medications out of Tennessee's waterways by disposing in one of our permanent pharmaceutical take back bins. There are nearly 100 take back bins located across the state, to find a convenient location please visit: <https://www.tnpharm.org/patient-resources/disposing-of-unwanted-drugs/>



Water Quality Data

What does this chart mean?

- **MCLG** - Maximum Contaminant Level Goal, or the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **MCL** - Maximum Contaminant Level, or the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.
- **MRDL**: Maximum Residual Disinfectant Level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for the control of microbial contaminants.
- **MRDLG**: Maximum residual disinfectant level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **AL** - Action Level, or the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow.
- **Below Detection Level (BDL)** - laboratory analysis indicates that the contaminant is not present at a level that can be detected.
- **Non-Detects (ND)** - laboratory analysis indicates that the contaminant is not present.
- **Parts per million (ppm) or Milligrams per liter (mg/l)** – explained as a relation to time and money as one part per million corresponds to one minute in two years or a single penny in \$10,000.
- **Parts per billion (ppb) or Micrograms per liter** - explained as a relation to time and money as one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.
- **Picocuries per liter (pCi/L)** - picocuries per liter is a measure of the radioactivity in water.
- **Millirems per year (mrem/yr)** - measure of radiation absorbed by the body.
- **Million Fibers per Liter (MFL)** - million fibers per liter is a measure of the presence of asbestos fibers that are longer than 10 micrometers.
- **Nephelometric Turbidity Unit (NTU)** - nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.
- **RTCR**– Revised Total Coliform Rule. This rule went into effect on April 1, 2016 and replaces the MCL for total coliform with a Treatment Technique Trigger for a system assessment.
- **TT** - Treatment Technique, or a required process intended to reduce the level of a contaminant in drinking water.

Contaminant	Violation Yes/No	Level Found	Range of Detections	Date of Sample	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Total Coliform Bacteria (RTCR)	No	0		2022		0	TT Trigger	Naturally present in the environment
Turbidity ¹	No	1.0	.02-1.0	2022	NTU	n/a	TT	Soil runoff
Copper	No	90 th %= 1.18		2022	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead ⁴	No	90 th %= ND		2022	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Sodium	No	1.57		2022	ppm	N/A	N/A	Erosion of natural deposits; used in water treatment
Ethylbenzene	No	.00126	N/A	8/30/22	ppb	700	700	Discharge from petroleum refineries
TTHM ⁶ [Total trihalomethanes]	No	0	0-0	2022	ppb	n/a	80	By-product of drinking water chlorination
Haloacetic Acids (HAA5)	No	0	0-0	2022	ppb	N/A	60	By-product of drinking water disinfection.
Xylenes, Total	No	.0137	N/A	8/30/22	ppm	10	10	Discharge from petroleum factories; discharge from chemical factories
Chlorine	No	1.90 Avg.	1.36-2.20	2022	ppm	4	4	Water additive used to control microbes.

Iron: Iron occurs naturally in our raw water and occasionally accumulates in the distribution system. Iron shows up as “red” or “rusty” water at your tap. Although you do not want to drink water that is not clear, iron is not considered to be a hazard to your health. We test for iron weekly and it is usually around 0 ppm. The aesthetic limit for iron is 0.3 ppm.

During the most recent round of Lead and Copper testing, only 0 out of 30 households sampled contained concentrations exceeding the action level.

¹100% of our samples were below the turbidity limit.

⁴Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested and flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the Safe Drinking Water Hotline (1-800-426-4791).

⁶ While your drinking water meets EPA's standard for trihalomethanes, it does contain low levels. Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

Health Effects

Microbiological Contaminants:

Total Coliform. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.
Turbidity. Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.

Inorganic Contaminants:

Copper. Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's Disease should consult their personal doctor.

Lead. Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure.

Volatile Organic Contaminants:

Ethylbenzene. Some people who drink water containing ethylbenzene well in excess of the MCL over many years could experience problems with their liver or kidneys.

TTHMs [Total Trihalomethanes]. Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

HAA [Haloacetic Acids]. Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.

Xylenes. Some people who drink water containing xylenes in excess of the MCL over many years could experience damage to their nervous system.

**6Important Information About Your Drinking Water
Monitoring Requirements Not Met for Hohenwald Water System**

Hohenwald Water System violated a drinking water standard over the past year. Even though this is not an emergency, as our customers, you have a right to know what happened and what we are doing (did) to correct these situations.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. During the second and third quarters of 2022, we failed to monitor for Total Trihalomethanes and Total Haloacetic Acids per our Stage 2 LRAA Monitoring Plan and therefore cannot be sure of the quality of your drinking water during that time. Also, during the second quarter of 2022, we did not monitor or test for Volatile Organic Contaminants (VOC) and therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

There is nothing you need to do at this time.

The table lists the contaminants we did not properly test for during the last year, how often we are supposed to sample for the contaminants and how many samples we are supposed to take, how many samples we took, when samples should have been taken, and the date on which follow-up samples were (or will be) taken.

Contaminant	Required sampling frequency	Number of samples taken	When all samples should have been taken	When samples were or will be taken
Total Trihalomethanes	Quarterly	2	5/11/2022	6/14/2022
Total Haloacetic Acids	Quarterly	2	5/11/2022	6/14/2022
Total Trihalomethanes	Quarterly	0	8/10/2022	None Taken
Total Haloacetic Acids	Quarterly	0	8/10/2022	None Taken
VOCs ¹	1 Sample each quarter	0	2 nd Quarter 2022	August 2022

What is being done?

System Communicated with TDEC and documented proper sampling dates according to the sampling plan.

¹ VOCs, also known as volatile organic compounds, are tested by collecting one sample and testing that sample for all the VOCs. VOCs are commonly used in industrial and manufacturing processes. VOCs include benzene, carbon tetrachloride, chlorobenzene, 1,2-dichlorobenzene, 1,4-dichlorobenzene, 1,2-dichloroethane, cis-dichloroethane, trans-dichloroethane, dichloromethane, 1,2-dichloropropane, ethylbenzene, styrene, tetrachloroethylene, 1,1,1-trichloroethane, trichloroethylene, toluene, 1,2,4-trichlorobenzene, 1,1-dichloroethylene, 1,1,2-trichloroethane, vinyl chloride, and xylene.

6. For more information, please contact Roger Newton at 931-796-2231 or 118 West Linden Ave., Hohenwald, TN 38462.

7.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being provided to you by Hohenwald Water System. State Water System ID# TN0000304.

Date Distributed: 6/6/2023